

**STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HIGHWAYS DIVISION**

ADDENDUM NO. 1

for

**KUAKINI HIGHWAY DRAINAGE IMPROVEMENTS
VICINITY OF MILE POST 114
ISLAND OF HAWAII
PROJECT NO. 11B-01-20**

The following is provided for information:

A. PRE-BID MEETING MINUTES

- i. Prebid Meeting was held on October 13, 2021 at 10:00 A.M. The meeting minutes, which includes the attendance list, is attached for information.

B. ANSWERS TO QUESTIONS FROM PROSPECTIVE BIDDERS

- i. Attached are RFIs and responses for your information.

C. AS-BUILT PLANS

- i. Attached are selected as-built plans for “Emergency Earthquake Rockfall Repairs, Various Locations on Hawaii, Unit 2, Federal-Aid Project No. ER-15(20)”, Sheet Nos. 1, 7, 15 and 16 that are for Kuakini Highway, Route 11, MP 114.1.

Please acknowledge receipt of this Addendum No.1 by recording the date of its receipt in the space provided on page P-4 of the Proposal.



JADE T. BUTAY
Director of Transportation

Addendum No. 1
r10/18/2021

KUAKINI HIGHWAY DRAINAGE IMPROVEMENTS
VICINITY OF MILE POST 114
PROJECT NO. 11B-01-20

PRE-BID MEETING NOTES
OCTOBER 13, 2021

The following notes are from the Hawaii Department of Transportation (HDOT) Pre-Bid Meeting with prospective bidders for the Kuakini Highway Drainage Improvements, Vicinity of Mile Post 114 project.

The meeting was conducted virtually via Microsoft TEAMS at 10:00 a.m.

A. Attendance List

1. HDOT Highways – Julann Sonomura, Laurence Tagorda, Aisha Sueda
2. WSP USA – Randall Urasaki
3. Geolabs – Gerald Seki
4. KSF – Russ Miyahara
5. Jas. W. Glover – Lizi Olson
6. Goodfellow Bros. – Jim Foss
7. Koga Engineering – Deron Spencer
8. Nan Inc. – Yanis Nora

B. General

1. The Pre-Bid Meeting is non-mandatory and is intended for clarification prior to bidding.
2. Anything said at this meeting is for clarification only. The bid documents shall govern over anything said today and discrepancies shall be clarified by addendum.
3. All requests for information (RFI), including any discussed at today's meeting, shall be received in writing via HlePRO no less than 14 calendar days before bid opening, which is on October 14, 2021 at 2:00 p.m. Questions received after the deadline will not be addressed. Verbal requests for information will not receive a response.
4. The minutes to this meeting including the list of attendees will be distributed by addendum prior to bid opening.
5. Deadline to submit bids is until 2:00 p.m. Hawaii Standard Time (HST), October 28, 2021. Bids received after said due date and time shall not be considered.

C. Open discussion with prospective bidder

1. No questions presented at the meeting.
2. There is one question posted on HlePRO that will be addressed by addendum.

D. The meeting was adjourned at 10:04 a.m.

**Questions for solicitation: B22000296 Kuakini Drainage Improvements, Vicinity
of Mile Post 114, Project No. 11B-01-20
10/14/2021**

1. Will segmented precast be allowed for the top portion, barrel, and base of the drain inlet structures? This will make construction more efficient and much more safe.

Response: Precast is acceptable. Contractor shall submit shop drawings stamped and signed by a registered Hawaii structural engineer.

2. Please provide As-Built Drawing for the toe and footing of the existing RIP-RAP wall at the proposed concrete curb beam location shown on plan sheet P-4.

Response: Requested As-Built Drawings are included as part of Addendum No. 1.