



Grated drain inlet filter shall be "Streamguard" Sediment Insert by Bowhead or pre-approved equal.

FILTER AT GRATED DRAIN INLET

Not to Scale



STABILIZED CONSTRUCTION ENTRANCE
Not to Scale




SECTION "B" 3 SEDIMENT CONTROL LOG


Not to Scale FED. ROAD DIST. NO. FED. AID PROJ. NO. FISCAL YEAR SHEET NO. STATE HSIP-0190(018) 2022 49 HAWAII

NOTES:

- Stake sediment logs in place with 2"x2"x30" wood stakes space no less than 24" apart unless otherwise noted. Drive stakes into ground a minimum of 6".
- 2. Staking shall be installed per manufacturer's recommendations.
- 3. Minimum overlap of sediment control logs shall be 2' on the horizontal plane.
- Install sediment control logs directly on ground making sure bottom of log is in full contact with ground. Tamp soil backfill against upstream side of log to assure storm water is forced flow through log rather than under it.








STOCKPILE PROTECTION DETAIL

TEMPORARY DUST CONTROL MEASURES

- The project site that is cleared shall be kept damp for (7) seven days a week. At the end of each day, the site shall be sufficiently dampened so that the site will remain moistened during the night.
- 2. The Contractor shall conduct his operations so that demolition, excavation, embankment, and imported material shall be dampened to prevent dust problems.



STATE OF HAWAII **DEPARTMENT OF TRANSPORTATION** HIGHWAYS DIVISION

EROSION CONTROL DETAILS

MAMALAHOA <u>HIGHWAY</u> SAFETY IMPROVEMENTS East and West of Puuwaawaa Ranch Federal Aid Project No. HSIP-0190(018)