

**STATE OF HAWAII  
DEPARTMENT OF TRANSPORTATION  
HIGHWAYS DIVISION**

**ADDENDUM NO. 1  
for  
AKONI PULE HIGHWAY PAVEMENT PREVENTIVE MAINTENANCE  
HAWI TOWN TO KAPAAU TOWN  
FEDERAL-AID PROJECT NO. STP-0270(020)**

The following amendment shall be made to the Bid Documents:

**A. PRE-BID MEETING MINUTES**

Attached are the June 6, 2011 Pre-Bid Meeting Minutes and attendance sheet for your information.

Please acknowledge receipt of this Addendum No. 1 by recording the date of its receipt in the space provided on page P-4 of the Proposal.

  
\_\_\_\_\_  
GLENN M. OKIMOTO, Ph.D.  
Director of Transportation

**DEPARTMENT OF TRANSPORTATION  
MEMORANDUM FOR RECORD**

**DATE:** June 6, 2012

HIGHWAYS  
**DIVISION**

HAWAII DISTRICT  
**BRANCH OR SECTION**

---

**NON-MANDATORY PRE-BID CONFERENCE FOR:**

AKONI PULE HIGHWAY PAVEMENT PREVENTIVE MAINTENANCE,  
HAWI TOWN TO KAPAAU TOWN, FEDERAL AID PROJECT NO. STP-0270(020),  
DISTRICT OF NORTH KOHALA, ISLAND OF HAWAII

**DATE, TIME & PLACE:**

June 6, 2012, 9:00 A.M.  
Hawaii District Office, Classroom D, 50 Makaala St., Hilo, HI, 96720.

**PARTICIPANTS:**

See attached Sign-In Sheet.

**BRIEF SUMMARY OF MEETING:**

1. A brief overview of the project was presented.
2. Questions and Answers:
  - a. Question: What are the working hours?

Response: The plans call for permitting the Contractor to work from 8:30am to 3:30pm.

*Post Response: More specifically, note number 7 of the General Notes, Sheet 3 of the plans, spells out the requirement to keep all lanes open to traffic between the peak morning hours of 6:30am to 8:30am and afternoon peak hours of 3:30pm to 5:30pm. The Contractor shall schedule his work, accordingly.*

- b. Question: Will there be problems with dealing macadam pavement while cold-planing?

Response: The State does not anticipate any problems with encountering of macadam pavement during this project.

- c. Question: Will the safety edge tapers be required for the project?

Response: Yes.

- d. Question: Is it necessary to pave behind guardrails?

Response: Yes, see typical section on plan sheet number 6 for details.

- e. Question: Is payment for pavement behind guardrail a separate item?

Response: No. Paving behind guardrails shall be paid for under the general pay item for HMA Mix No. IV, Item No. 401.0400.

- f. Question: Is it permissible for the Contractor use warm mix asphalt?

Response: Yes, the option for warm mix asphalt is provided under Special Provisions, Section 401.

**PRE-BID CONFERENCE (NON-MANDATORY)**

Project: Akoni Pule Highway - Route 270 M.P. 21.22-23.47

## Federal-Aid

Project No. STP-0270(020)

**Date & Time:** June 6, 2012 9:00 A.M. (50 MAKAALA ST., HILO, HI.)

[illegible]