


NOTES:

1. PRIMARY LOOP SYSTEM SHALL BE MAINTAINED AT ALL TIMES.
2. CABLES WITHIN RGS AND TRANSFORMERS LAID ON SURFACE MUST BE SECURED TO SURFACE AND PROTECTED FROM DAMAGE FROM VEHICLES, AIRCRAFT AND JET BLAST IN A MANNER ACCEPTABLE TO THE ENGINEER.
3. TEMPORARY EDGE LIGHT FIXTURES SALVAGED FROM DEMOLITION.
4. TEMPORARY EDGE LIGHTS & CONDUIT SHALL BE ANCHORED FROM JET BLAST.
5. IN LIEU OF REUSING SALVAGED EDGE LIGHTS, BATTERY POWERED PORTABLE EDGE LIGHTS MEETING AC 150/5345-50B MAY BE USED IF APPROVED BY THE ENGINEER.
6. USE OF TEMPORARY EDGE LIGHTS THAT RESULTS IN A MIX OF INCANDESCENT AND LED FIXTURES ILLUMINATING THE RUNWAY EDGE, IS NOT ACCEPTABLE.

TYPICAL-TEMPORARY RUNWAY/
TAXIWAY EDGE LIGHTS DETAIL
SCALE: N.T.S.

1
E3.06




SECTION A-A

NOTES:


1. MATCH HOLE PATTERN TO EXISTING LIGHT BASE. PATTERN SHOWN IS FOR SIZE B, 12\"/>

TYPICAL - BREAK-OUT RING
SCALE: N.T.S.


2
E3.06



Airports Division
DEPARTMENT OF TRANSPORTATION
STATE OF HAWAII



CHRISTOPHER T. BRISKORN
LICENSED PROFESSIONAL ENGINEER
PE-19550
HAWAII, U.S.A.



CHRIS BRISKORN, PE
ELECTRICAL ENGINEER

4/30/24
Expiration Date

DSGN.	DRWN.	CHKD.	APPD.
HF	HT	JB	DY

KEY PLAN / NOTES:

NO.	DATE	REVISIONS
CONSTRUCTION DOCUMENTS		
JULY 2022 DATE		
PROJECT TITLE :		
RELOCATE RUNWAY 3-21		
AT LIHUE AIRPORT LIHUE, KAUAI, HAWAII		
PROJECT NO.:		
AK1031-14		
SHEET TITLE:		
TEMPORARY EDGE LIGHTING DETAILS		
DATE :		DWG. NO. E3.06
07/2022		
SHEET :		
350 OF 376 SHEETS		

C:\USERS\GALLARDO\BBOX\LIHUE\RSA\900-CAD-GIS\900-CAD-20-SHEETS\E3.06.DWG