

SECTION 629 - PAVEMENT MARKINGS

Make the following amendments to said Section:

(I) Amend **Subsection 629.03(B) – Temporary Pavement Markings** by revising the third paragraph from line 62 to 63 to read:

“Maintain and replace temporary pavement markings, flexible delineators, and barricades. ”

(II) Amend **Table 629.03 – 1 – Temporary Pavement Markings** to read as follows:

“TABLE 629.03-1 TEMPORARY PAVEMENT MARKINGS	
TYPE	PAVEMENT MARKINGS
Passing Permitted - Both Sides	Single 4-inch yellow stripe 5 feet in length spaced 20 feet on center with Type D markers spaced 40 feet on center and located on center of 5-foot length of stripe.
Passing Prohibited - Both Sides	Double solid 4-inch yellow stripes with Type D markers placed 20 feet on center on one of 4-inch yellow stripes selected by the Engineer.
Passing Permitted - One Side Only	Single continuous 4-inch yellow stripe with Type D markers placed on stripe 20 feet on center on no-passing side and single 4-inch yellow stripes 5 feet in length spaced 20 feet on center on passing side.
Lane Lines - Lane Changing Permitted	Single 4-inch yellow or white stripe 5 feet in length spaced 20 feet on center with Type C or Type D markers spaced 40 feet on center.
Lane Lines - Lane Changing Prohibited	Double solid 4-inch white stripes with Type C markers placed 20 feet on center on one of the 4-inch white stripes selected by the Engineer.
Crosswalk	Two 12-inch white transverse lines spaced 8 feet on center or as ordered by the Engineer.
Stop Line	Single 12-inch white transverse line.
Note: Paint may be used for temporary markings in areas where final paving is not complete.”	

(III) Amend **Subsection 629.03(D) – Removal of Existing Pavement Markings** from lines 288 to 290 to read:

19 “(4) **Other.** Remove preformed pavement marking tape by methods
20 recommended by manufacturers. Eradication of existing markings by
21 painting over them will not be allowed.
22

23 Removal of existing pavement markings during cold planning operations
24 shall not be paid for separately and will be considered incidental to
25 415.0110 – Cold Planing of Existing Pavement. “
26

27 **(IV) Amend 629.04 – Measurement** by revising lines 292 to 294 to read as
28 follows:
29

30 **“629.04 Measurement.**

31
32 (A) The Engineer will measure thermoplastic and preformed pavement
33 marking tape per linear foot in accordance with the contract
34 documents. The longitudinal pavement markings will be measured per
35 linear foot as a single stripe for the width specified in the contract and
36 in the proposal.
37

38 The Engineer will measure the transverse markings by the linear
39 foot, per lane, or per each according to the contract.
40

41 The Engineer will not measure temporary pavement markings
42 including flexible delineator posts with reflector markers or Type I
43 Barricades and temporary signs installed for the longitudinal guidance
44 of public traffic over reconstructed areas, cold planed surfaces, newly
45 paved surfaces or other unmarked or scarified areas for payment.
46

47 The Contractor shall consider the work required for the removal of
48 pavement markings incidental to the various contract items, except as
49 provided in the proposal or elsewhere in the contract. If the contract
50 stipulates that the Engineer will make payment for the removal of
51 pavement markings, the Engineer will measure the removal of
52 pavement markings.
53

54 (B) The Engineer will measure the pavement markers per each for the
55 types shown in the proposal.
56

57 (C) The Engineer will measure the painted stripes that are twelve (12)
58 inches wide or less as a single stripe. The Engineer will measure the
59 painted stripes over twelve (12) inches wide as two (2) stripes. The
60 Engineer will measure the double stripes that are twelve (12) inches or
61 less in total width including the transverse space between the stripes
62 as a single stripe.
63

64 The Engineer will measure the longitudinal pavement markings by
65 the linear foot or per gallon according to the contract. Longitudinal
66 gaps for skip striping will not be included in the measurement.
67

68 The Engineer will measure the transverse markings by the linear
69 foot, per lane, per each or per gallon according to the contract.
70

71 The Engineer will measure the curb markings by the linear foot or
72 per gallon according to the contract.”
73

74 (V) Amend **629.05 – Payment** by revising lines 296 to 330 to read as follows:
75

76 **“629.05 Payment.**
77

78 (A) The Engineer will pay for thermoplastic and preformed pavement
79 marking tape at the contract price per linear foot or on a lump sum
80 basis according to the contract, complete in place, including primers.
81

82 The Engineer will pay for double four (4) inch striping with a four (4)
83 inch space between stripes at the contract price per linear foot or on a
84 lump sum basis according to the contract.
85

86 The Engineer will pay for crosswalk markings at the contract price
87 per lane of traffic marked, per each or on a lump sum basis according
88 to the contract.
89

90 The Engineer will pay for pavement arrows (single and multiple
91 heads), symbols, and words at the contract price per each according to
92 the contract.
93

94 The contract unit price paid shall be full compensation for furnishing
95 labors, materials, tools, equipment and incidentals and for doing the
96 work involved in furnishing and installing pavement markings complete
97 in place according to the contract.
98

99 The Engineer will not pay for the temporary pavement markings
100 including flexible delineator posts with reflector markers or Type I
101 Barricades and temporary signs installed for the longitudinal guidance
102 of public traffic over reconstructed areas, cold planed surfaces, newly
103 paved surfaces or other unmarked or scarified areas for payment if not
104 shown in the proposal separately. The Engineer will consider them
105 incidental to the various contract items.
106

107 If the contract specifies payment for removal of pavement markings
108 under unit price pay items, the Engineer will pay for the accepted
109 quantities at the contract unit prices bid. The prices shall be full
110 compensation for removing such items according to the contract.

(B) The Engineer will pay for the various types of pavement markers at the contract price per each or on a lump sum basis according to the contract, complete in place, including adhesives.

(C) The Engineer will pay for painted pavement striping at the contract price per linear foot or on a lump sum basis according to the contract.

The Engineer will pay for quantities of crosswalk marking at the contract price per lane of traffic marked, per each or on a lump sum basis according to the contract.

The Engineer will pay for pavement arrows (single or multiple arrow heads), symbols, and words at the contract price per each according to the contract.

The Engineer will pay for the accepted quantities of curb markings at the contract price per linear foot or on a lump sum basis.

The Engineer will pay for the following pay items when included in the proposal schedule:

Pay Item	Pay Unit
_____ - Inch Pavement Striping (_____)	Linear Foot
Pavement Word (Thermoplastic Extrusion)	Each
Pavement Arrow (Thermoplastic Extrusion)	Each
Pavement Symbol (Thermoplastic Extrusion)	Each
Yield Line (Thermoplastic Extrusion)	Lane
Crosswalk Marking (Thermoplastic Extrusion)	Lane
Type _____ Pavement Marker	Each
Removing and Disposing of _____	Linear Foot
Removing and Disposing of _____	Each
Removing and Disposing of _____	Lane
Thermoplastic Rumble Bars	Linear Foot

END OF SECTION 629

**STP-0700(089)
629-4a**

**Addendum No. 1
r11/23/22**