	SECTION 712 - MISCELLANEOUS	
Make	e the following amendment to said Section:	
(I) follow	Amend <b>712.07(A)</b> Frame and Cover from line 98 to line 112 to read ws:	l as
	"(A) Frame and Cover. Frame and cover for manhole handhole shall meet requirements of AASHTO M 306."	or
(II) follow	Amend <b>712.07(B)</b> Frame and Grate from line 114 to line 132 to read ws:	i as
	<b>(B)</b> Frame and Grate. Cast iron frame and grate shall conform AASHTO M 306, unless steel is specified in the contract documents.	n to
	Steel frame and grate shall conform to ASTM A 283/A 283 M, GraD; ASTM A 27/A 27M, Grade 65-35; or ASTM A 47/A 47 M, Grade 350 Zinc coating shall be provided in accordance with ASTM A 123/A 123M.	)18.
	Steel frames and grate that compiles with ASTM A 283/A 283 Grade D shall be zinc coated in accordance with ASTM A 123/A 123 M.	
	Reinforcing steel for grate shall conform to Subsection 709.0 Reinforcing Steel. Frame and grate shall be cleaned thoroughly a painted on all sides that will not be imbedded in concrete with one coahigh-grade asphalt conforming to ASTM A 849, Class M, Fully Coated shop. Second coat of paint shall be applied on all sides not imbedded concrete just before the pre-final inspection. Any damage to the zide coating of a frame or grate shall be repaired in accordance with ASTM A using a Zinc-based solder coating. Zinc rich paints shall not be used for repair of zinc coating that has been damaged.	and it of I, at d in inc- 780
	Fabricated frame and grate shall be true to line and free of twist bends, and open joints. Splices will not be allowed. Cut surfaces a edges shall be made smooth by machining or grinding before fabrication frame and grate.	and
	Size and length of weld shall be as specified in contract documer Welds shall be free of defects, discontinuities and shall have penetration."	

47