

SECTION 629 - PAVEMENT MARKINGS

Make the following amendments to said Section:

(I) Amend **Subsection 629.03(B) – Temporary Pavement Markings** by revising the third paragraph from line 62 to 63 to read:

“Maintain and replace temporary pavement markings, flexible delineators, and barricades.”

(II) Amend **Table 629.03 – 1 – Temporary Pavement Markings** to read as follows:

“TABLE 629.03-1 TEMPORARY PAVEMENT MARKINGS	
TYPE	PAVEMENT MARKINGS
Passing Permitted - Both Sides	Single 4-inch yellow stripe 5 feet in length spaced 20 feet on center with Type D markers spaced 40 feet on center and located on center of 5-foot length of stripe.
Passing Prohibited - Both Sides	Double solid 4-inch yellow stripes with Type D markers placed 20 feet on center on one of 4-inch yellow stripes selected by the Engineer.
Passing Permitted - One Side Only	Single continuous 4-inch yellow stripe with Type D markers placed on stripe 20 feet on center on no-passing side and single 4-inch yellow stripes 5 feet in length spaced 20 feet on center on passing side.
Lane Lines - Lane Changing Permitted	Single 4-inch yellow or white stripe 5 feet in length spaced 20 feet on center with Type C or Type D markers spaced 40 feet on center.
Lane Lines - Lane Changing Prohibited	Double solid 4-inch white stripes with Type C markers placed 20 feet on center on one of the 4-inch white stripes selected by the Engineer.
Crosswalk	Two 12-inch white transverse lines spaced 8 feet on center or as ordered by the Engineer.
Stop Line	Single 12-inch white transverse line.
Note: Paint may be used for temporary markings in areas where final paving is not complete.”	

(III) Amend **629.04 – Measurement** by revising lines 292 to 294 to read as follows:

18
19 **"629.04 Measurement.**

20
21 **(A)** The Engineer will measure thermoplastic and preformed pavement
22 marking tape per linear foot in accordance with the contract documents.
23 The longitudinal pavement markings will be measured per linear foot as a
24 single stripe for the width specified in the contract and in the proposal.
25 The Engineer will include the longitudinal gaps for skip striping, up to thirty
26 (30) feet long, in the measurement.

27
28 The Engineer will not measure temporary pavement markings
29 including flexible delineator posts with reflector makers or Type I
30 Barricades and temporary signs installed for the longitudinal guidance of
31 public traffic over reconstructed areas, cold planed surfaces, newly paved
32 surfaces or other unmarked or scarified areas for payment.

33
34 The Engineer will measure the temporary pavement markings and
35 temporary signs installed as ordered by the Engineer for special
36 temporary traffic patterns on a force account basis, if the contract specifies
37 payment in the proposal.

38
39 The Contractor shall consider the work required for the removal of
40 pavement markings incidental to the various contract items.

41
42 **(B)** The Engineer will measure the pavement markers per each for the
43 types shown in the proposal.

44
45 **(C)** The Engineer will measure the painted stripes that are twelve (12)
46 inches wide or less as a single stripe. The Engineer will measure the
47 painted stripes over twelve (12) inches wide as two (2) stripes. The
48 Engineer will measure the double stripes that are twelve (12) inches or
49 less in total width including the transverse space between the stripes as a
50 single stripe.

51
52 The Engineer will measure the longitudinal pavement markings by
53 the linear foot or per gallon according to the contract. Longitudinal gaps
54 for skip striping that are 30 feet or less will be included in the
55 measurement.

56
57 The Engineer will measure the transverse markings by the linear
58 foot, per lane, per each or per gallon according to the contract."

59
60 **(IV) Amend 629.05 – Payment** by revising lines 296 to 330 to read as follows:

61
62 **"629.05 Payment.**

(A) The Engineer will pay for thermoplastic and preformed pavement marking tape at the contract price per linear foot according to the contract, complete in place, including primers.

The Engineer will pay for double four (4) inch striping with a four (4) inch space between stripes at the contract price per linear foot according to the contract.

The contract unit price paid shall be full compensation for furnishing labors, materials, tools, equipment and incidentals and for doing the work involved in furnishing and installing pavement markings complete in place according to the contract.

The Engineer will not pay for the temporary pavement markings including flexible delineator posts with reflector markers or Type I Barricades and temporary signs installed for the longitudinal guidance of public traffic over reconstructed areas, cold planed surfaces, newly paved surfaces or other unmarked or scarified areas for payment if not shown in the proposal separately. The Engineer will consider them incidental to the various contract items.

The Engineer will compute the actual amount paid to the Contractor for force account work according to Subsection 109.06 – Force Account Provisions and Compensation.

(B) The Engineer will pay for the various types of pavement markers at the contract price per each according to the contract, complete in place, including adhesives.

The Engineer will pay for the following pay items when included in the proposal schedule:

Pay Item	Pay Unit
_____ - Inch Pavement Striping (Type _____ Tape or Thermoplastic)	Linear Foot
Type _____ Pavement Marker	Each"

END OF SECTION 629