

1                                   **SECTION 706 - CONCRETE, CLAY AND PLASTIC PIPE**  
2

3       Make the following amendments to said Section:  
4

5       **(I)**       Amend **Subsection 706.02(A) RCP for Drainage System** from lines 8 to 28  
6       to read as follows:  
7

8               **“(A) RCP for Drainage System.** RCP shall conform to AASHTO Load and  
9       Resistance Factor Design (LRFD) specifications, and AASHTO M 170 for  
10      specified diameters and strength class, and requirements below:  
11

12               **(1)**      Acceptance shall be based on:  
13

14                       **(a)**      Plant Certification from the American Concrete Pipe  
15                       Association (ACPA), National Precast Concrete Association  
16                       (NPCA), or Precast/Prestressed Concrete Institute (PCI).  
17

18                       **(b)**      Certified Plant Load Bearing Test results.  
19

20                       **(c)**      Certified Material Test results.  
21

22                       **(d)**      Inspection for visual defects and imperfections of the  
23                       manufactured pipe.  
24

25               **(2)**      Using three-edge-bearing test method, pipe shall be loaded  
26                       until 0.01-inch crack occurs. Pipe manufacturer shall furnish facilities  
27                       and provide personnel to perform test according to AASHTO T 280  
28                       (ASTM C 497). Each section of pipe, in addition to required pipe  
29                       markings, shall include project identification and inspection lot  
30                       designation.  
31

32               **(3)**      Precast reinforced concrete pipe end sections shall conform to  
33                       the requirements above.”  
34  
35

36  
37                                   **END OF SECTION 706**  
38  
39  
40  
41  
42  
43  
44  
45  
46