

- 1
- 2
- 3
- 4
- 5
- 6
- 7
- 8
- 9
- 10
- 11
- 12
- 13
- 14
- 15
- 16
- 17
- 18
- 19
- 20
- 21
- 22
- 23
- 24
- 25
- 26
- 27
- 28
- 29
- 30
- 31
- 32
- 33
- 34
- 35
- 36
- 37
- 38
- 39
- 40
- 41
- 42

(l) Amend **712.07(B) Frame and Grate** from line 114 to line 132 to read as follows:

Frame and grate shall also conform to Americans with Disabilities Act Accessibility Guidelines (ADAAG) and Standards Section 302.3 Openings. Grate shall have a maximum of one-half inch (½”) opening in direction perpendicular to travel.

Fabricated frame and grate shall be true to line and free of twists, bends, and open joints. Splices will not be allowed. Cut surfaces and edges shall be made smooth by machining or grinding before fabrication of frame and grate.

Size and length of weld shall be as specified in contract documents. Welds shall be free of defects, discontinuities and shall have full penetration.”

**STP-0560(017)**  
**712-1a**

**3/30/06**