1 2

4

SECTION 407 – TACK COAT

3 Make the following amendment to said Section:

5 **(I)** Amend **Section 407.03(D) - Application of Tack Coat**, from lines 63 to 72 to read:

7

8 "Apply tack coat on existing asphalt or concrete surface, or both, to be 9 overlayed by HMA or PMA course. Once water has evaporated from asphalt 10 emulsion, tack coat is said to have set. Place HMA or PMA overlay after tack 11 coat has set and within four hours of application. For multiple lift construction of 12 HMA or PMA, tack coat application will not be waived. Remove all deleterious 13 material to bonding before applying the tack coat to the entire surface to receive 14 the next lift.

15

16 Before placing HMA or PMA course, apply tack coat to contact surfaces of curbs, gutters, manholes, other structures, vertical faces of existing 17 pavements, and exposed transverse and longitudinal edges of each course. 18 19 Apply tack coat on all surfaces that will have an asphalt pavement placed on it in 20 a uniform, full coverage manner, e.g., no visible streak, holidays in the application, no differences in the application rate, i.e., the thickness of the tack 21 22 coat. The exception to this requirement shall be surfaces that will have pavement joint adhesive applied to it which shall not require any tack coat." 23

- 24
- 25 26
- 20
- 28

END OF SECTION 407