


GALVANIZED CAST IRON CHECKED COVER


SIDEWALK PULL BOX FOR FLUSH MOUNTING

NOT TO SCALE

F-3









NOTES:

 STEEL REINFORCEMENT SHALL BE USED IN DUCT BANKS UNDER ROADWAYS TO 3 FEET BEYOND EDGE OF ROADWAY AND THE LAST 3 FEET OF DUCTBANKS ENTERING STRUCTURES.
 DIMENSIONS SHOWN ARE MINIMUM.









THIS WORK WAS PREPARED BY ME OR UNDER MY SUPERVISION.

June 1 Signature

STATE OF HAWAII

DEPARTMENT OF TRANSPORTATION

HIGHWAYS DIVISION

ELECTRICAL DETAILS #1


MAUI DISTRICT BASEYARD


REPAIR AND MAINTENANCE OF
BUILDINGS AND GROUNDS, PHASE 3
PROJECT NO. HWY-M-08-04M

SCALE: AS SHOWN

DATE: MAY 2005


SHEET No. E-3 OF 10 SHEETS






NOTES:

- 1. PROVIDE GROUNDING IN ALL HANDHOLES.
- 2. INSCRIBE 2" HIGH X 1/8" DEEP LETTERS ON CONCRETE COVER: "SECONDARY" - POWER (UNDER 600V) AND CONTROL - TELEPHONE & SCADA
- 3. ALL HANDHOLES SHALL BE RATED FOR LIVE LOADS.




2 MOUNTING ADAPTER YOKE (FOR OUTDOOR LIGHTS)

NOT TO SCALE
E-4



WALL BRACKET (FOR OUTDOOR LIGHTS)

NOT TO SCALE
E-4



STATE OF HAWALL DEPARTMENT OF TRANSPORTATION HIGHWAYS DIVISION

ELECTRICAL DETAILS #2

MAUI DISTRICT BASEYARD REPAIR AND MAINTENANCE OF BUILDINGS AND GROUNDS, PHASE 3 PROJECT NO. HWY-M-08-04M

SCALE: AS SHOWN

DATE: MAY 2005 SHEET No. E-4 OF 10 SHEETS