

FED. ROAD DIST. NO. FISCAL SHEET TOTAL YEAR NO. SHEETS PROJ. NO. **HAW.** | HWY-M-06-06M | 2010

ELECTRICAL SYMBOLS

- & existing ceiling luminaire to be removed
- New Ceiling Luminaire
- S New Switch, +4'-0"
- *← existing panelboard*
- existing junction box to be removed
- (3) existing junction box to remain
- (E) existing equipment connection
- **⊢** *New Junction Box*
- EP **Explosionproof**
- WP Weatherproof
- ---- wiring in existing raceway to be removed
- * -x- * wiring in existing raceway to be removed
- ---- New Wiring in Raceway Concealed in Floor or Below Grade
- ---- New Wiring in Exposed Raceway
- --- EP -- New Wiring in Explosion Proof Raceway
- 1. Any Circuit With No Further Designation Indicates A Two Wire Circuit. Circuits with Additional Wires are
 - Indicated as Follows: 4, 3 Wires: 4, 4 Wires, Etc.
 - 2. Ground Wire Per National Electrical Code Indicated as Follows: —
 - 3. All Exposed Conduit and Boxes Shall Be Painted to Match Adjacent Wall or Ceiling Surrounding



EXPRATION DATE OF THE LICENSE 4/30/2012
THIS WORK WAS PREPARED BY
ME OR UNDER MY SUPERVISION

STATE OF HAWAII DEPARTMENT OF TRANSPORTATION HIGHWAYS DIVISION

ELECTRICAL SYMBOLS, LUMINAIRE DETAIL, ELECTRICAL SITE PLAN

KEANAE BASEYARD MAINTENANCE and REPAIRS Project No. HWY-M-06-06M

Scale: AS NOTED Date: APRIL 2010 SHEET No. *E-100* OF *18*

SHEETS

