
FED. ROAD DIST. NO.	STATE	PROJ. NO.	FISCAL YEAR	SHEET NO.	TOTAL SHEETS
HAWAII	HAW.	HWY-0-09-06	2008	45	46

New Panel "A1"		120/240 Volts		1ø, 3WSN		
2P70A	Main Bkr.	Branch Bkr I.C	•	10,000 Amps		
Surface	e, 20" Wid	le Cabinet, Industrial—Bolted, NE	MA 4X Stainless S	Steel		
CKT	BKR	LOAD	K	KVA		
NO.	DAK	LUAD	L1	L2	- WIRE	
1	2P20A	SP-1	1.0		10	
2,4	2P70A	WSP-1	6.6	6.6	4	
3	1P	PFB				
5	1P	P F B				
6						
7						
8						
9						
10						
11						
12						
13						
14						
15						
16						
17						
18	*					
TOTAL			7.6	6.6		




SINGLE LINE DIAGRAM (WAIANAE BASEYARD)

ELECTRICAL SYMBOLS

- Duplex Convenience Outlet, 3W2OA, Ground Fault Interrupter Type, +16" Unless Otherwise Noted
- \bullet Wall Junction box, 4-11/16" Square Minimum
- □ Large Junction Box
- Panelboard
- existing panelboard
- © Equipment Connection
- → Safety Switch
- **WP** Weatherproof
- Wiring In Raceway Concealed In Wall Or Ceiling
- —— Wiring In Raceway Concealed In Floor Or Below Grade
- ---- Wiring In Exposed Raceway

- 1. Any Circuit With No Further Designation Indicates A Two Wire Circuit. Circuits With Additional Wires Are Indicates As Follows: -/-, 3 Wires: -//-, 4 Wires, Etc.
- 2. Ground Wire Per National Electrical Code Indicated As Follows: —
- 3. All Exposed Conduit And Boxes Shall Be Painted To Match Adjacent Wall Or Ceiling Surrounding



STATE OF HAWAII DEPARTMENT OF TRANSPORTATION
HIGHWAYS DIVISION

P. SCHED., ELECT'L SYMB., DIAGRAM (WAIANAE BASEYARD)

KANEOHE, PEARL CITY AND WAIANAE
BASEYARD WASHDOWN RACKS
Project No. HWY-0-09-06

Date: MAY 2008 Scale:

SHEET No. E-300 OF 46 SHEETS

