



































































ELECTRICAL SYMBOL LIST / MOUNTING HEIGHT SCHEDULE				
MOUNTING HEIGHT FROM FLOOR TO		(SPECIAL MOUNTING HEIGHTS INDICATED ON PLAN)		
		SYMBOL		DESCRIPTION
TOP	℄	EXISTING	NEW	
				LUMINAIRE, 1'X4' NOMINAL, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE
				LUMINAIRE, 1'X4' NOMINAL, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE, WITH INTEGRAL EMERGENCY BATTERY PACK
				LUMINAIRE, LINEAR, WALL MOUNTED
				LUMINAIRE, LINEAR, WALL MOUNTED WITH INTEGRAL EMERGENCY BATTERY PACK
				LUMINAIRE, 2'X4' NOMINAL, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE
				LUMINAIRE, 2'X4' NOMINAL, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE, WITH INTEGRAL EMERGENCY BATTERY PACK
				LUMINAIRE, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE
				LUMINAIRE, MOUNTING STYLE AS INDICATED IN LIGHT FIXTURE SCHEDULE, WITH INTEGRAL EMERGENCY BATTERY PACK
				ILLUMINATED EXIT SIGN, WALL MOUNTED, DIRECTIONAL ARROWS AS INDICATED
				ILLUMINATED EXIT SIGN, CEILING MOUNTED, DIRECTIONAL ARROWS AS INDICATED
46"		\$	\$	LIGHT SWITCH, WALL MOUNTED, 1P20A, 120/277V, 1HP MAXIMUM
46"		\$ <sup>a</sup>	\$ <sup>a</sup>	LIGHT SWITCH, WALL MOUNTED, 1P20A, 120/277V, 1HP MAXIMUM (LETTER INDICATES LUMINAIRES CONTROLLED)
46"		\$ <sub>3</sub>	\$ <sub>3</sub>	THREE WAY SWITCH, WALL MOUNTED, 20A, 120/277V
				OCCUPANCY SENSOR, CEILING MOUNTED
46"			\$ <sub>LV</sub>	LOW VOLTAGE SWITCH
46"			\$ <sub>OS</sub>	OCCUPANCY SENSOR SWITCHPACK/RELAY

ELECTRICAL SYMBOL LIST / MOUNTING HEIGHT SCHEDULE				
MOUNTING HEIGHT FROM FLOOR TO		(SPECIAL MOUNTING HEIGHTS INDICATED ON PLAN)		
		SYMBOL		DESCRIPTION
TOP	℄	EXISTING	NEW	
	18"			RECEPTACLE, WALL MOUNTED, DUPLEX, GROUNDING TYPE, 125V, NEMA TYPE 5-20R
	18"			RECEPTACLE, WALL MOUNTED, DUPLEX, GFCI TYPE, 125V, NEMA TYPE 5-20R
	18"			RECEPTACLE, WALL MOUNTED, QUADRUPLEX, GROUNDING TYPE, 125V, NEMA TYPE 5-20R
				RECEPTACLE, WALL MOUNTED, DUPLEX, 125V, NEMA 5-20R, 6" ABOVE COUNTER TOP
				RECEPTACLE, WALL MOUNTED, DUPLEX, GFCI TYPE, 125V, NEMA 5-20, 6" ABOVE COUNTER TOP
				JUNCTION BOX, LARGE, WALL MOUNTED
18"				JUNCTION BOX, WALL MOUNTED
				MOTOR
				NON-FUSED DISCONNECT SWITCH, 3P30A UNLESS OTHERWISE NOTED, VOLTAGE TO MATCH CIRCUITING
60"				ENCLOSED CIRCUIT BREAKER
				TRANSFORMER, WALL MOUNTED
				TRANSFORMER, PAD OR FLOOR MOUNTED
72"				PANELBOARD
	6"			RECEPTACLE, WALL MOUNTED SINGLE, RANGE-TYPE, 125/250V, NEMA TYPE 14-50R WITH MATCHING PLUG CAP
	18"			RECEPTACLE, WALL MOUNTED, SINGLE, SPECIAL PURPOSE, 125V, NEMA CONFIGURATION AS NOTED
	18"			ISOLATED GROUND RECEPTACLE, DUPLEX, NEMA 5-20R, WALL MOUNTED
	18"			ISOLATED GROUND RECEPTACLE, QUADPLEX, NEMA 5-20R, WALL MOUNTED
				HOMERUN ARROW TO PANELBOARD. LETTER INDICATES PANELBOARD, NUMBERS INDICATES CIRCUITS.
				INTERIOR WORK: CONCEALED CONDUIT IN FINISHED FLOOR OR BELOW GRADE (NO HASHMARKS INDICATE 2 CURRENT CARRYING CONDUCTORS AND 1 GROUND CONDUCTOR WITHIN, ALL OTHERS SIMILAR).  EXTERIOR WORK: CONCRETE ENCASED UNDERGROUND DUCT LINE, SEE DUCT SECTION INDICATOR AND SCHEDULE.
				CONCEALED CONDUIT IN CEILING OR WALLS, (HASHMARKS INDICATE 3-WIRES WITHIN, ALL OTHERS SIMILAR).
				EXPOSED RACEWAY, PROVIDE STRAP 8'-0" ON CENTER MAXIMUM
				DENOTES DEMOLITION/REMOVAL
				DENOTES DEMOLITION/REMOVAL



Airports Division  
DEPARTMENT OF TRANSPORTATION  
STATE OF HAWAII



Ross N. Takai

04/30/2024  
Licensed Expiration Date

This work was prepared by me or under my supervision.

DSGN.	DRWN.	CHKD.	APPD.

NO.	DATE	REVISIONS

DATE

PROJECT TITLE :

NEW PASS AND ID OFFICE

AT  
DANIEL K. INOUE INTERNATIONAL AIRPORT  
HONOLULU, OAHU, HAWAII

PROJECT NO.:

CO1322-63

SHEET TITLE:

ELECTRICAL  
SYMBOL LIST

DATE :	DWG. NO. <div>E-001</div>
12/21/22	
SHEET :	
062 OF 100	