

NOT TO SCALE

FED. ROAD DIST. NO. STATE FED. AID PROJ. NO. FISCAL SHEET NO. SHEETS

HAWAII HAW. NH-STP-0300(164) 2021 119 119

NOTES:

- 1. Pole and foundation shall withstand winds up to 108 MPH gusting without permanent deformation.
- 2. Provide 1" Sch 80 PVC conduit between pole foundation and cabinet. Conduit shall be buried in accordance with Standard Plan TE-36.
- 3. Conduit shall emerge from direct burial next to the cabinet foundation and then extend 4" above grade.
- 4. Conduit ends shall be sealed to keep conduit clean and dry until installation of cable(s) from the pole to the cabinet.

STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION

TRAFFIC COUNTING STATION
POLE AND FOUNDATION DETAILS

INTERSTATE H-2 and MOANALUA FREEWAY, PHASE 2

Guardrail and Shoulder Improvements
Federal Aid Proj. No. NH-STP-0300(164)

Scale: NTS

Date: August, 2020

SHEET No. 119 OF 119 SHEETS

119 OF 119 SI