

STATE OF HAWAII
DEPARTMENT OF TRANSPORTATION
HIGHWAYS DIVISION

ADDENDUM NO. 2
for
SLOPE IMPROVEMENTS FOR EROSION CONTROL
AT VARIOUS SITES ON OAHU, PHASE 5
PROJECT NO. HWY-O-01-12

The following amendments shall be made to the Bid Documents:

A. NOTICE TO BIDDERS

1. Amend the **NOTICE TO BIDDERS** as follows:

NOTICE TO BIDDERS

Prospective bidders are hereby notified that receiving of sealed proposals scheduled for May 24, 2012 will be postponed and rescheduled for 2:00 P.M., Hawaii Standard Time (HST), May 31, 2012.

B. SPECIFICATIONS

1. Amend **Section 618.03(C) – Site Preparation** by revising lines 64 to 70 to read as follows:

“(C) Site Preparation. For all Sites except Sites 2, 3, 5, 6, 15, 16, and 17: Loosen compacted soils to a depth of twelve (12) inches and uniformly spread a two inch layer of compost. Only loosen the soil and spread compost in the area for which soil preparation can be completed by the end of the work day. Compost must be incorporated into the soil within seven (7) days of spreading. Protect loosened soil at the end of the work day.”

2. Amend **Section 618.03(C) – Site Preparation** by adding the following after line 80:

“Sites 2, 3, 6, 15, 16, and 17: Site preparation shall be conducted in accordance with Section 208 - Leveling of Surfaces.”

3. Amend **Section 618.03(D) – Soil Amendment and Tilling** by revising lines 82 to 87 to read as follows:

“(D) Soil Amendment and Tilling. For all Sites except Sites 2, 3, 6, 15, 16, and 17: Spread two inches of compost and till into top six (6) inches of soil. Only till an area for which work can be completed by the end of the work day. Do not till within eighteen inches of pavement edges. Protect all tilled areas from erosion at the end of the work day.”

4. Amend **Section 618.03(D) – Soil Amendment and Tilling** by adding the following

after line 90:

"No soil amendments or tilling work will be required for sites 2, 3, 6, 15, 16 and 17."

5. Amend **Section 673.02(G) - Grouted Soil/Rock Anchors** by revising line 77 to read as follows:


"Yield Load Capacity 63 kips (280 kN)"

C. PLANS

1. Amend **Sheet No. 9** by revising Anchored Wire Mesh System Materials Note #7 to read as follows:

"The grouted soil and/or rock anchor shall consist of hollow threaded bar with outside and inside diameters of 1.25 and 0.59 inches, respectively, and minimum yield load capacity of 63 kips. The non-shrink grout shall be non-shrink, non-metallic, non-gaseous and shall have a minimum unconfined compressive strength of 4,000 psi or greater."

Please acknowledge receipt of this Addendum No. 2 by recording the date of its receipt in the space provided on page P-4 of the Proposal.



GLENN M. OKIMOTO, Ph.D.
Director of Transportation