

HECO NOTES

1. The location of HECO's overhead and underground facilities shown on the plans are from existing records with varying degrees of accuracy and are not guaranteed as shown. The Contractor shall exercise extreme caution whenever construction crosses or is in close proximity of underground lines and shall maintain adequate clearance when operating equipment within or under any overhead lines.
2. The Contractor shall comply with the State of Hawaii's Occupational Safety and Health Law (DOSH).
3. The Contractor shall obtain an excavation permit from HECO's Mapping and Records Division located at 820 Ward Avenue, 4th floor, two weeks prior to starting construction.
4. For verification of underground lines or for assistance in supporting and protecting these lines, the Contractor shall call HECO's Underground Division at 543-7345 a minimum of 72 hours in advance.
5. When trench excavation is adjacent to or beneath our existing structures or facilities, the Contractor is responsible for:
  - a. Sheeting and bracing the excavation to prevent slides, caveins, and settlements.
  - b. Protecting existing structures or facilities with beams, struts, or under-pinnings.
6. For pole bracing instructions, the Contractor shall call the HECO District Superintendent at (Koolau/261-6085, Waiau/543-4223, Ward/543-7745) a minimum of 72 hours in advance.
7. Any work required to relocate HECO facilities shall be done by HECO and the Contractor shall be responsible for all coordination, and for possible costs it applicable.
8. Should it become necessary to temporarily relocate any of HECO facilities to enable the Contractor to perform his work in a safe and expeditious manner in fulfilling his contract obligations, these temporary relocations will be done by HECO, or by the Contractor under HECO's supervision, with all costs borne by the Contractor.
9. Any unforeseen conflict that would result in the redesign or relocation (either temporary or permanent) of HECO's electrical facilities may be cause for lengthy delays. To avoid such delays, the Contractor must notify HECO of the conflict a minimum of 30 days prior to the start of construction.
10. Any damage to HECO's facilities will be reported immediately to HECO's Trouble Dispatcher at 543-7874.
11. All HECO overhead and underground facilities shall be protected at all times by the Contractor during construction. Costs for damages to HECO facilities shall be borne by the Contractor. This repair work shall be done by HECO, or by the Contractor under HECO's supervision.
12. The Contractor shall indemnify, defend and hold harmless HECO from and against all losses, damages, claims and actions, all expenses incidental to such losses, damages, claims or action, based upon or arising out of damage to property or injuries to persons, or other tortious acts caused or contributed to by Contractor or anyone acting under its direction or control or on its behalf; provided Contractor's indemnity shall not be applicable to any liability upon the sole negligence of HECO.

BOARD OF WATER SUPPLY NOTES

1. Unless otherwise specified, all materials and construction of water system facilities and appurtenances shall be in accordance with the City and County of Honolulu Board of Water Supply's "WATER SYSTEM STANDARDS" VOLUME 1, DATED 1985, THE "APPROVED MATERIAL LIST AND STANDARD DETAILS FOR WATER SYSTEM CONSTRUCTION", VOLUME 2, DATED 1985, THE "WATER SYSTEM EXTERNAL CORROSION CONTROL STANDARDS", VOLUME 3, DATED 1991, and all subsequent amendments and additions.
2. All plans approved by the Board of Water Supply are based solely on the adequacy of the water supply. All other features of the water system, such as lines, grades, fittings, drainage, etc., and other features if improvements shall not be the responsibility of the Board of Water Supply.
3. The existence and location of underground utilities and structures as shown on the plans are from the latest available data but is not guaranteed as to the accuracy or the encountering of other obstacles during the course of the work. The Contractor shall be responsible and pay for all damages to existing utilities. The Contractor shall not assume that where no utilities are shown, that none exist.
4. The Contractor shall be responsible for the protection of all water lines during construction. The Contractor shall be especially careful when excavating behind water lines, tees, and bends wherever there is a possibility of water line movement due to the removal of the supporting earth beyond the existing reaction blocks. The Contractor shall take whatever measure necessary to protect the water lines, such as constructing special reaction blocks (with BWS approval) and/or modifying his construction method.
5. Re-approval shall be required if this project is not under construction within a period of two years.
6. At the electrical/signal ductline water crossings, adjust all electrical/signal ductline elevations to maintain 6" vertical clear separation from all waterlines (12" clear for all electrical/signal ductline structures larger than 16") at no cost to the Board of Water Supply.
7. Maintain 3'-0" min. horizontal clear separation between all waterline systems and nearest electrical/signal ductlines paralleling the water system at no cost to the Board of Water Supply.
8. Maintain 3'-0" min. horizontal clear separation between street light/traffic signal, standards (including any modular units) and the nearest water system. Contractor shall field verify for any conflicts at each street light/traffic signal standard location. Where conflicts occur, the contractor shall coordinate with the project engineer to revise the street light/traffic signal standard to provide the required clearances at no cost to the BWS.
9. The Contractor shall notify BWS Planning and Engineering Division, Construction Section, one week prior to commencing work on the water system.
10. The Contractor shall verify all existing service lateral locations whether shown or not shown on plans prior to commencing with any of the work and shall not assume that where no services are shown none exist.
11. Prior to any excavating, the Contractor shall verify in the field the location of existing water mains and appurtenances.


FED. ROAD DIST. NO.	STATE	PROJ. NO.	FISCAL YEAR	SHEET NO.	TOTAL SHEETS
HAWAII	HAW.	63A-01-96	1996	3	11

CONSTRUCTION NOTES FOR GAS FACILITIES

1. BHP Gas Company gas pipelines in the project area are plastic coated and cathodically protected. The Contractor shall be extremely careful when working near the gas pipeline.
2. Prior written clearance must be obtained from BHP Gas Company, Maps and Records Department, 515 Kamakee Street, at least five working days before starting excavation near any of BHP Gas Company pipelines.

Since pipeline locations on field maps are approximate, the Contractor, after obtaining written clearance, shall call BHP Gas Company, a minimum of five working days before starting excavation to arrange for field location of existing gas lines. The telephone number is 594-5575 during business hours, and 526-0066 after hours.
3. The Contractor shall notify BHP Gas Company, Distribution Department (594-5556) 24 hours prior to excavating and backfilling any pipeline.
4. The Contractor shall have the sole responsibility to perform field verification, including hand digging methods.
5. The Contractor shall excavate and backfill around the pipeline in the presence of a representative of BHP Gas Company. All backfill within 6 inches of any gas pipeline shall be sand, mansand or select cushion material approved by BHP Gas Company.
6. The Contractor shall notify BHP Gas Company immediately after any damage has been caused to the existing gas pipelines, their coatings or their cathodic protection devices. The number to call is 594-5567 or 526-0066, 24 hours a day. The Contractor shall be liable for any damage to BHP Gas Company facilities. Repair work on this damage shall be performed by BHP Gas Company with payment for this work to be borne by the Contractor.
7. Minimum vertical and horizontal clearance between gas pipeline and other pipelines, conduits, or other structures shall be 12 inches. Adequate support and protection for gas pipelines exposed in the trench shall be provided by the Contractor and approved by BHP Gas Company.
8. The Contractor shall work in an expeditious manner in order to keep uncovered gas line exposure to a minimum.
9. Existing gas lines are 500 psi High Pressure gas lines. It's recommended that Contractor hand-dig to expose gas line before excavating with machinery.

DATE	3/11/96
SURVEY PLOTTED BY	
DRAWN BY	M. Takahashi
DESIGNED BY	C. Abe
NOTED BY	H. Miyagi
CHECKED BY	K. Higashimura
ORIGINAL PLAN	
NOTED BOOK	

APPROVED:	Date 5/13/96
	
Chief, Planning & Engineering, BWS	

STATE OF HAWAII DEPARTMENT OF TRANSPORTATION HIGHWAYS DIVISION	
<b>GENERAL NOTES</b>	
<b>KALIHI STREET</b>	
<b>Intersection Improvements at</b>	
<b>Nimitz Highway</b>	
<b>Project No. 63A-01-96</b>	
Not To Scale	Date: Apr., 1996
SHEET No. 1	OF 1 SHEETS