

<u>Notes:</u>

- 1. All stanchions shall be installed at same height.
- 2. Stationary galv. pipe to be filled with concrete to weigh approximately 150 lbs.
- 3. Welded nuts are for screwing in bolts to act as handles for lifting removable stanchions. Bolt to be removed after installation.
- 4. Stanchions shall be painted yellow per ANSI spec. Z53.1 to comply with OSHA standards per color coding.
- 5. Stanchion shall comform to ASTM A53.




APPROVED BY:

HAWAIIAN ELECTRIC COMPANY, INC.

DATE

FED. ROAD DIST. NO. STATE FED. AID PROJ. NO. FISCAL SHEET NO. SHEETS

HAWAII HAW. STP-8930(2) 2007 303 331



DEPARTMENT OF TRANSPORTATION HIGHWAYS DIVISION

MISCELLANEOUS DETAILS

<u>North-South Road</u> <u>Phase 1B</u> F.A.I. Proj. No. STP-8930(2)

Scale: AS NOTED
REVISION SHEET

DATE

AS NOTED Date: Feb 21, 2007

SHEET No. E2.22 OF 62 SHEETS

303